



CITY OF GRAND RAPIDS

1/31/03

Kerkstra Precast Inc.
1330 Chicago Dr
Jenison MI 49428

Attn: Dan VanDyke

Dear Mr. VanDyke:

I reviewed the information you supplied regarding the 1000-gallon grease interceptor. I took into consideration the 30-year track record of this product and that it surpasses the PDI-G101 standard that is a requirement for this device. Using the authority of Section 105.2 in the 2000 Michigan Plumbing Code, we the City of Grand Rapids will accept the use of this product within our system for it's intended use.

Please contact me at 456-3157 if you have any questions or concerns.

Sincerely,

Marv Schierbeek
Chief Plumbing Inspector
456-3157

MS/nad



CITY OF GRAND RAPIDS

1/31/03

Kerkstra Precast Inc.
1330 Chicago Dr
Jenison MI 49428

Attn: Dan VanDyke

Dear Mr. VanDyke:

I reviewed the information you supplied regarding the 1000-gallon grease interceptor. I took into consideration the 30-year track record of this product and that it surpasses the PDI-G101 standard that is a requirement for this device. Using the authority of Section 105.2 in the 2000 Michigan Plumbing Code, we the City of Grand Rapids will accept the use of this product within our system for it's intended use.

Please contact me at 456-3157 if you have any questions or concerns.

Sincerely,

Marv Schierbeek
Chief Plumbing Inspector
456-3157

MS/nad